

APPENDIX - VIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 831

Date : 12/06/25

It is certified that an inspection team headed by En. Khushpal Singh.
Sub-divisional Engineer (Name of Officers
with designation) from WSS & Sanitation Subdiv. Nabha. (Name of
Department/Office) inspected the Dayanand Public School
Pandunar street Nabha. (Name & Address of
the School) on 12/06/25 and found that the Dayanand Public School
Pandunar street Nabha. (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T. Govt.

The above valid for a period of 12/06/25 to 31/03/26.


Sub Divisional Engineer
Water Supply & Sanitation
Sub Division, NABHA

Signature with Seal :

Name : En. Khushpal Singh.

Designation : S.D.E

To

Principal,
Dayanand Public School
Pandunar street Nabha

(Name & Address of the Institution)

**TRADE WASTE AND EFFLUENTS RESEARCH UNIT (REGIONAL LAB)
PATIALA**

Room No. 301, 2nd Floor, Water Supply & Sanitation Department, Head Office, Nabha Road, Patiala
researchunitpatiala@yahoo.in

To,

Dayanand Public School __
Pandusar Street, Nabha

No.: TWERU/2526/00107 Dated : 19/05/2025

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 3935 Dated: 14/05/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 14/05/2025. It is request to fill the attached feedback form and send it back to Trade Waste and Effluents Research Unit (Regional Lab) Patiala

D/A : Test Report

**Authorized Signatory
For, Trade Waste and Effluents Research Unit
(Regional Lab) Patiala**

TRADE WASTE AND EFFLUENTS RESEARCH UNIT (REGIONAL LAB)

PATIALA

Room No. 301, 2nd Floor, Water Supply & Sanitation Department, Head Office, Nabha Road, Patiala
 researchunitpatiala@yahoo.in

TEST REPORT

Name & Address of Customer : Dayanand Public School _____ Pandusar Street, Nabha		Customer Reference No.	No : 3935 Dated : 14/05/2025			
		Sample Submitted by	Udit Sharma			
		Date of Sample Receipt	14/05/2025			
		Analysis Starting Date	15/05/2025			
		Analysis completion Date	19/05/2025			
Discipline : Chemical Testing		Group: Water				
ULR No.:	TC14242250000185F	Sample Type :	Water			
Test Report No.:	TWERU/2526/00107	Date of Issue :	19/05/2025			
Registration no.:	TWERU/REG2526/00934	Condition of Sample :	Unsealed			
Collection Point:	Private Submersible	Quantity/Type of Bottle:	2000 ml / Plastic Bottles			
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Submersible at Dayanand Public School, Pandusar Street , Depth- 138m, Nabha. / NA			
Village :	Not Mentioned	Habitation :	Not Mentioned			
Block:	Not Mentioned	District :	Patiala			
Latitude :	Not Mentioned	Longitude:	Not Mentioned			
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	6.94	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	TDS	110	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
3	Turbidity	0.15	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
4	Alkalinity(CaCO ₃)	60	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
5	Hardness(CaCO ₃)	48	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
6	Calcium(Ca)	10	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
7	Magnesium(Mg)	6	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
8	Fluoride(F)	0.10	1.0	1.5	mg/l	APHA 24th Ed.2023, Method 4110
9	Chloride(Cl)	10	250	1000	mg/l	APHA 24th Ed.2023, Method 4110
10	Nitrate(NO ₃)	21	45	No Relaxation	mg/l	APHA 24th Ed.2023, Method 4110
11	Sulphate(SO ₄)	10	200	400	mg/l	APHA 24th Ed.2023, Method 4110
12	Iron	BDL(0.2)	1	No Relaxation	mg/l	APHA 3111-B (23rd Ed. 2017) by AAS
13	Manganese	BDL(0.1)	0.1	0.3	mg/l	APHA 3111-B (23rd Ed. 2017) by AAS

Continue on next page...

Reviewed and Approved By

Sh. Brij Bhushan
 Quality Manager
 Authorized Signatory
 For, Trade Waste and Effluents Research Unit
 (Regional Lab) Patiala

TRADE WASTE AND EFFLUENTS RESEARCH UNIT (REGIONAL LAB)

PATIALA

Room No. 301, 2nd Floor, Water Supply & Sanitation Department, Head Office, Nabha Road, Patiala
researchunitpatiala@yahoo.in

14	Zinc	0.5472	5	15	mg/l	APHA 3111-B (23rd Ed. 2017) by AAS
15	Arsenic(As)	BDL(0.005)	0.01	No Relaxation	mg/l	APHA 3114 (23rd Ed. 2017) by HVG-AAS
16	Residual Chlorine(RC)	BDL(0.17)	0.2	1	mg/l	IS-3025 (Part-26) by Iodometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduced wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit: 50 ±20%

Reviewed and Approved By



Sh. Brij Bhushan
Quality Manager
Authorized Signatory
For, Trade Waste and Effluents Research Unit
(Regional Lab) Patiala

----- End of the Test Report -----